

# Incident Notification

## Dropped Object struck Steel Fixer

### What Happened

Two Steel Fixers were standing a 6m long vertical bar on the wall in the west box. The Steel Fixers stated the bar contacted a 200mm long Scaffold Tube extension piece which has caused it to dislodge from the scaffold structure above and drop approximately 6-8m striking one of the steel fixers on the right shoulder. Steel fixer received first aid on site.



Dropped Object

### Immediate Actions Taken

- Incident reported to anagement
- WorkSafe and Comcare notified
- Investigation underway

*Please review this notification with your team, and consider similar exposures in your area. Further information will be provided once the investigation is complete.*